



RPTs vs SPRPTs: What's the difference?

Category	RPTs	SPRPTs
UL standard listing	UL 1363	UL 1363A
UL guide information	XBYS	XBZN2
Intended purpose	Indoor use as an extension of a grounding alternating-current branch circuit for general use	Indoor use with medical equipment (when the medical equipment is intended to be used in general or critical care patient care areas per Article 517 of the NEC)
Labeling symbol	Standard UL label 	UL component label 
RPT Use Requirements		
CMS waiver requirement for equipment use	Any equipment except equipment in the patient care vicinity	Only patient care-related equipment in the patient care vicinity
Area of use, 1999 edition of NFPA 99: <i>Standard for Health Care Facilities</i>	General care areas outside the patient care vicinity	Critical care areas and general care areas in the patient care vicinity
Area of use, 2012 edition of NFPA 99: <i>Health Care Facilities Code</i>	Support rooms and basic and general care rooms outside the patient care vicinity	Critical care rooms and basic care and general care rooms in the patient care vicinity

RPT – relocatable power tap

SRPT – special purpose relocatable power tap

NEC – NFPA 70: *National Electrical Code*®